Report Date: 9/14/2022 Report Time: 4:05 PM EDT

Region II Hotline Log Entry Information

Data ID: 701509

Date Of Report: 10/24/2009 **NRC #:** 921573 **State #:** NONE **ERNS #:**

Material Type: Oil Receiver: Hriczko

Material / Amount: DIELECTRIC FLUID (466 GALLON(S));

Location: Street:

City: MANHATTAN

County: NEW YORK (MANHATTAN)

State: NY Latitude: Longitude:

Source of Pollution: CON-ED
Water Body: HARLEM RIVER

State Or EPA Responded: PRP is responding to spill. NYCDEP

Initial EPA Action: Contacted the RP to get a follow-up. See Action Report.

Status: 2 - Closed

URL:

Associated Action Reports

DataID: 0268523

 Date: 10/25/2009
 Time: 11:20

 Duty Officer/Responder Name: Bonnie Hriczko
 NRC Report #: 921573
 Hotline Log DataID: 701509

Action Information

Description: 1014 hours the OSC contacted Con-Edison to get an update on the status of the spill. Spoke with Dave Duke from their environmental group who informed me that the spill of mineral oil/dielectric fluid is still ongoing. The estimated quantity is 4,600 gallons, but it continues to leak at a rate of 350-400 gallons per hour. The location is 196th Street and Cedric Ave. in the Bronx. There is a 10' pipe below ground at that location that has a leak. They believe that the oil is getting into the combined sewer system, which will ulimately reach the treatment plant. They have a boat deployed on the Harlem River to monitor for sheen in case any oil bypasses the sewer. They would like a representative of the NYC DEP on-scene to verify that the oil

cannot leave the sewer system, so that they can release the boat.

1051 hours the OSC contacted the NYC DEP to notify them of the incident and request that they respond to the spill location and assist Con-Edison with their spill response. I gave them all of the spill information and they assured me that a

representative with respond shortly.

1104 hours the OSC contacted Con-Edison back and assured them that a rep from the NYCDEP will be responding shortly. I notified him that a new duty officer would be taking over at noon and that he can contact him directly should he have any

follow-up information or need assistance.

1108 hours the OSC briefed the upcoming duty officer (Budroe).

Follup-Up:

Person Contacted

Name: David Duke

Organization: Con-Edison (Environmental)

Phone #: 908-420-4487

NRC Spill Report

NATIONAL RESPONSE CENTER 1-800-424-8802

GOVERNMENT USE ONLYGOVERNMENT USE ONLY***

Information released to a third party shall comply with any

applicable federal and/or state Freedom of Information and Privacy Laws

Incident Report # 921573

INCIDENT DESCRIPTION

*Report taken by: E5 LEON TROY at 23:53 on 24-OCT-09

Incident Type: FIXED
Incident Cause: UNKNOWN
Affected Area: HARLEM RIVER

The incident occurred on 24-OCT-09 at 23:40 local time.

Affected Medium: WATER HARLEM RIVER

REPORTING PARTY

Name: JOHN MORAN

Organization: CON-ED
Address: 128 WEST END AVE

NEW YORK, NY 10001

CON-ED called for the responsible party.

PRIMARY Phone: (212)5806763

INCIDENT LOCATION

CEDAR MIKE 51 County: NEW YORK (MANHATTAN)

City: MANHATTAN State: NY

WEST 49TH STREET SUBSTATION TO SPRAINBROOK SUBSTATION

RELEASED MATERIAL(S)

CHRIS Code: NCC Official Material Name: NO CHRIS CODE

Also Known As: DIELECTRIC FLUID

Qty Released: 466 GALLON(S) Qty in Water: 0 UNKNOWN AMOUNT

DESCRIPTION OF INCIDENT

CALLER IS REPORTING A SPILL OF 466 GALLONS OF DIELECTRIC FLUID FROM CEDAR MIKE 51 DUE TO UNKNOWN CAUSES. CALLER STATED CEDAR MIKE 51 IS A TRANSMISSION FEEDER. CALLER

STATED THEY HAVE A LEAK RATE OF 186 GALLONS PER HOUR.

SENSITIVE INFORMATION

INCIDENT DETAILS

Package: N/A Building ID:

Type of Fixed Object: OTHER

Power Generating Facility: UNKNOWN

Generating Capacity: Type of Fuel:

NPDES:

NPDES Compliance: UNKNOWN

---WATER INFORMATION--Body of Water: HARLEM RIVER

Tributary of:

Nearest River Mile Marker:

Water Supply Contaminated: UNKNOWN

REPORTING PARTY

Type of Organization: PUBLIC UTILITY

SUSPECTED RESPONSIBLE PARTY

Name: JOHN MORAN Organization: CON-ED

Address: 128 WEST END AVE
NEW YORK, NY 10001

PRIMARY Phone: (212)5806763

Type of Organization: PUBLIC UTILITY

IMPACT

Fire Involved: NO Fire Extinguished: UNKNOWN

INJURIES: NO Hospitalized: Empl/Crew: Passenger: FATALITIES: NO Empl/Crew: Passenger: Occupant:

EVACUATIONS: NO Who Evacuated: Radius/Area:

Damages: NO

Hours Direction of

<u>Closure Type</u> <u>Description of Closure</u> <u>Closed</u> <u>Closure</u>

Air: N

Road: N Major Art N

Waterway: N

Track: N

Passengers Transferred: NO Environmental Impact: UNKNOWN

Media Interest: NONE Community Impact due to Material:

REMEDIAL ACTIONS

CALLER STATED PFT VANS ARE RUNNING THE FEEDER AND CREWS ARE CHECKING MAN HOLES AND

POWER STATIONS.
Release Secured: NO

Release Rate:

Estimated Release Duration:

WEATHER

Weather: PARTLY CLOUDY, 66 F

ADDITIONAL AGENCIES NOTIFIED

Federal: NONE State/Local: NONE

State/Local On Scene: NONE
State Agency Number: NONE

NOTIFICATIONS BY NRC

ATLANTIC STRIKE TEAM (MAIN OFFICE)

25-OCT-09 00:07 (609)7240008

CT DEPT OF EMERGENCY MGMT (COMMISSIONER)

25-OCT-09 00:07 (860)2560800

DOT CRISIS MANAGEMENT CENTER (MAIN OFFICE)

25-OCT-09 00:07 (202)3661863

U.S. EPA II (MAIN OFFICE)

(732) 3214370

NATIONAL INFRASTRUCTURE COORD CTR (MAIN OFFICE)

25-OCT-09 00:07 (202)2829201

NJ OFC HMLND SECURITY & PREPAREDNES (COMMAND CENTER)

25-OCT-09 00:07 (609)9636817

NJ STATE POLICE (MARINE SERVICES BUREAU)

25-OCT-09 00:07 (609)9636900

NOAA RPTS FOR NY (MAIN OFFICE)

25-OCT-09 00:07 (206)5264911

BUREAU TOXIC SUBSTANCE R. WILBURN (MAIN OFFICE)

25-OCT-09 00:07 (518)4027810

NY STATE DEC SPILL HOTLINE (MAIN OFFICE)

25-OCT-09 00:07 (518) 4577362

SECTOR NEW YORK (COMMAND CENTER)

(718) 3544353

NJ DEP POC: DUTY OFFICER (MAIN OFFICE)

25-OCT-09 00:07 (609)5882848
USCG DISTRICT 1 (COMMAND CENTER)
25-OCT-09 00:07 (617)2238555

ADDITIONAL INFORMATION

CALLER HAD NO ADDITIONAL INFORMATION.

*** END INCIDENT REPORT #

Report any problems or Fax number changes by calling 1-800-424-8802

PLEASE VISIT OUR WEB SITE AT http://www.nrc.uscg.mil